

# 2025 SCHEDULE 22 SUMMARY REPORT

BAXTER  
DISTRIBUTION SYSTEM



For the period of  
January 1<sup>st</sup>, 2025 to December 31<sup>st</sup>, 2025

Prepared for the Corporation of the Township of Essa by the Ontario Clean Water Agency



This report was prepared in accordance with the requirements of [O.Reg 170/03, Schedule 22, Summary Reports for Municipalities](#) for the following system and reporting period:

<b>Drinking-Water System Number:</b>	220004064
<b>Drinking-Water System Name:</b>	Baxter Distribution System
<b>Drinking-Water System Owner:</b>	The Corporation of the Township of Essa
<b>Drinking-Water System Category:</b>	Small Municipal Residential
<b>Period being reported:</b>	January 1, 2025 – December 31, 2025

## 1. Issue(s) of Non-Compliance

An unannounced Ministry of Environment, Conservation and Parks (MECP) Drinking Water System Inspection was conducted on May 27, 2025 for the period covering April 1, 2024 to May 27, 2025. On August 19, 2025 the Inspection Report was issued. An Inspection Summary Rating Record (IRR) of 100% was received.

The following is a summary of non-compliances noted in the MECP Inspection Report, as well as the duration and the measures that were taken to correct the non-compliance. If any self-reported non-compliances were included in the inspection report, they will be noted in Table 1.

**Table 1. Non-Compliances and Corrective Actions noted in the 2024/2025 MECP Inspection Report**

Non-Compliance(s)	Duration	Required Actions & Corrective Actions
N/A	N/A	N/A

The following table (Table 2) is a summary of any incidents that the Operating Authority interpreted as instances where any requirements of the Act, the regulations, the system’s approval, drinking water works permit (DWWP), municipal drinking water licence (MDWL), and any orders applicable were not met. The Operating Authority reported the following incidents to the MECP and confirmation of whether the incidents are considered non-compliances are noted in the MECP Inspection Report and included in Table 1.

**Table 2. Self-Reported Incidents and Corrective Actions for the Reporting Period**

Incident	Duration	Corrective Actions
N/A	N/A	N/A

For information on any Adverse Water Quality Incident(s) that may have occurred during the reporting period, please refer to the Baxter Distribution System Annual Report (Section 11).

## 2. Assessment of Flowrates and Quantity of Water Supplied

In 2017, Baxter Drinking Water System became a stand-alone distribution system receiving treated water from the Raymond A. Ultrafiltration Plant owned by the Town of Collingwood. Treated water is transported via a water transmission main (pipeline) that stretches from the Town of Collingwood to Alliston, in the Township of New Tecumseth.

The Township of Essa has an agreement in place with the Township of New Tecumseth to receive up to 400 m<sup>3</sup>/day (effective as of July 1, 2024) from the pipeline to accommodate the new Baxter development and build-out. The balance of the 400 m<sup>3</sup>/day that is not taken by the Baxter DS is sent to the Mill Street Pumphouse in Angus, Ontario. Since treated water is supplied to the distribution system, Baxter DS does not have a Permit to Take Water, as it does not draw from a raw water source.

In September 2023, OCWA began preparing for the new Baxter Booster Station to come online, as part of pre-approved works to the system. On December 6, 2023, the old pumphouse on Marshall Avenue was decommissioned and the treated water from the pipeline began entering the newly commissioned Baxter Booster Station on Murphy Road in Baxter and in turn began conveying water to the distribution system.

The following tables (Table 3 and 4) summarize the quantities and flowrates of water received from the New Tecumseth Pipeline and then supplied to the Baxter Distribution System during the reporting period, including average and maximum day volumes as well as a comparison to the allowable takings approved in the system's approval, DWWP or MDWL.

### 2.1 Treated Water

<b>Municipal Drinking Water License (MDWL):</b>	118-102 (Issue Number: 4)
<b>Allowable Rated Capacity:</b>	Not Applicable
<b>Allowable Flowrate into Treatment System:</b>	Not Applicable

The applicable MDWL does not contain an allowable rated capacity or allowable flowrate into the treatment system. Rated capacity is assessed based on the contractual agreement between the Township of Essa and the Township of New Tecumseth, which stipulates that the Baxter Distribution System may take up to 400 m<sup>3</sup>/day (effective July 1, 2024) of treated water from the transmission pipeline.

**Table 3. Treated Water Annual and Monthly Average and Maximum Flows with Comparison to the New Tecumseth Pipeline Allowable Daily Takings and Total Volume for 2025**

Timeframe	Average Daily Takings (m <sup>3</sup> /day)	Maximum Daily Takings (m <sup>3</sup> /day)	Total Volume Taken (m <sup>3</sup> )
January	93.95	115.06	2,912.48
February	96.05	196.99	2,689.33
March	92.49	307.54	2,867.13
April	91.27	341.33	2,738.22
May	64.88	186.78	2,011.33
June	95.71	195.35	2,871.23
July	159.80	341.73	4,953.76
August	125.74	289.31	3,897.89
September	67.52	109.17	2,025.70
October	58.42	77.45	1,811.05
November	47.51	131.01	1,425.27
December	58.13	400.64	1,801.99
<b>2025</b>	<b>87.69</b>	<b>400.64</b>	<b>32,005.38</b>

A review of flow information for the reporting period indicates that the Baxter distribution system operated within the allowable taking volume stipulated in the contract between the Township of Essa and the Township of New Tecumseth (400 m<sup>3</sup>/day (effective July 1, 2024)).

## 2.2 Distribution Water

**Table 4. Distribution Water Annual and Monthly Average and Total Flow for 2025**

2025 Flow from the Baxter Pumphouse to the Distribution System		
Timeframe	Average Daily Flow (m <sup>3</sup> /day)	Total Flow (m <sup>3</sup> /day)
January	96.70	2,997.57
February	98.14	2,747.88
March	97.53	3,023.40
April	84.69	2,540.64
May	66.28	2,054.68
June	98.33	2,949.91
July	164.07	5,086.28
August	121.37	3,762.52
September	70.26	2,107.75
October	57.36	1,778.07
November	55.67	1,670.01
December	62.09	1,924.77

<b>2025 Flow from the Baxter Pumphouse to the Distribution System</b>		
<b>Timeframe</b>	<b>Average Daily Flow (m<sup>3</sup>/day)</b>	<b>Total Flow (m<sup>3</sup>/day)</b>
<b>2025</b>	<b>89.43</b>	<b>32,643.49</b>

The applicable MDWL and contact do not list a maximum allowable limit for flow or flowrate of water that flows into the distribution system.